

# R.P.C. ELECTRICAL SERVICES & MAINTENANCE.

MOBILE: 07907456340

## Electrical Equipment Testing (PAT)

Original Certificate **11317** Certificate reference **113 EDP**

### DETAILS OF CLIENT

Client/Address: **EDITPOST PHOTOGRAPHY**

### TESTING DETAILS

Test Equipment used **ETH15S** Serial Number **9125**  
 Tested by **R.P.C.** Date **17-2-23** Retest Date **17-2-24**

Number	Description	Location	Class	Visual	Earth	Insulation	Repair
1	NET GEAR 1		A	OK	OK	>20MΩ	N/A
2	NET GEAR 2		A	OK	OK	720MΩ	N/A
3	NET GEAR 3		A	OK	OK	720MΩ	N/A
4	NET GEAR 4		A	OK	OK	720Ω	N/A
5	enlinchrom Lite1		A	OK	OK	720Ω	N/A
6	enlinchrom Lite2		A	OK	OK	720Ω	N/A
7	enlinchrom Lite3		A	OK	OK	720Ω	N/A
8	enlinchrom Lite4		A	OK	OK	720Ω	N/A
9	enlinchrom Lite5		A	OK	OK	720Ω	N/A
10	enlinchrom Lite6		A	OK	OK	720Ω	N/A
11	Dell Laptop 1		A	OK	OK	720Ω	N/A
12	Dell Laptop 2		A	OK	OK	720Ω	N/A
13	Dell Laptop 3		A	OK	OK	720Ω	N/A
14	Dell Laptop 4		A	OK	OK	720Ω	N/A
15	CP-D70 Printer		A	OK	OK	720Ω	N/A
16	CP-D70 Printer		A	OK	OK	720Ω	N/A
17	CP-D70 Printer		A	OK	OK	720Ω	N/A
18	Laptop Compaq		A	OK	OK	720Ω	N/A
19	Laptop Compaq		A	OK	OK	720Ω	N/A
20	EXT 1		A	OK	OK	720Ω	N/A
21	EXT 2		A	OK	OK	720Ω	N/A
22	EXT 3		A	OK	OK	720Ω	N/A
23	EXT 4		A	OK	OK	720Ω	N/A
24	EXT 5		A	OK	OK	720Ω	N/A
25	EXT 6		A	OK	OK	720Ω	N/A
26	EXT 7		A	OK	OK	720Ω	N/A
27	T.V Samsung		A	OK	OK	720Ω	N/A
28	T.V Samsung		A	OK	OK	720Ω	N/A